



**SPECIFICATION:**

CONCRETE: MINIMUM 4,000 PSI  
 REINFORCEMENT: ASTM A-615, GRADE 60  
 LOAD: H-20 LOADING  
 PIPE CONNECTORS: MEET OR EXCEED ASTM C923  
 JOINT BUTYL SEALANT: MEETS OR EXCEED C990 SPECIFICATIONS  
 RISERS TO BRING TO ACCESS TO GRADE SOLD SEPARATELY

APPROX. WT:  
20,600 lbs.

DRAWN BY:  
A.L.

Tank Type: 1,500 GALLON 2 COMPARTMENT STEG

DATE: 8/26/19

COPYRIGHT 2019  
LEE'S PRECAST